




# NOTE SHEET

4


The Technical Expert Committee examined the File Bearing no. - 0125189231400165 for Fire Safety Certificate for An Existing of G+III storied building, Named - "Kabi Sukanta Secondary Teachers Training Institute". Under Group - Educational. Address - Mouza - Reapara, J.L. No. - 130, Plot No. - 1886, 1888, 1872/2184, P.S. - Nandigram, Dist - Purba Medinipur, Pin - 721650. Height - 14.25Mtr. Abutting road - 06Mtr. Side open space - N - other building (Reapara PTTI), S - 2.8 Mtr. E - 2.5 Mtr. W - 7.7 Mtr. Exit/Ent. - 1 nos. U/G - 20000 ltrs., O/H - 6000 ltrs. as per approved plan drawing and Recommended for issue of Fire Safety Certificate by the Director General, West Bengal Fire & Emergency Services.


  
24.11.23  
Shri Ar. Prantik Adhar Samanta (Sr. Architect - Member)

  
24/11/23  
Sri Tanmay Mohapatra S/E (Member - Sr. Electrical Engineer (WBSIEDCL))

  
Sri. Atanu Maity EE(PWD) (Member)

  
24/11/23  
Shri. Shyamal Kumar Mondal Dy SP (DEB)  
(Member - Representative of Commissioner of S.P. Police, Paschim Medinipur)

  
24/11/23  
Divisional Fire Officer - Paschim Medinipur, Purba Medinipur & Jhargram  
(Member - Convener)

  
24/11/23  
Director, WBF & ES  
(Member)

  
24/11/23  
Director General, Fire & Emergency Services  
(Chairman)

2/3



Government Of West Bengal  
Office Of The Divisional Fire Officer, Paschim Medinipur  
West Bengal Fire & Emergency Services  
Sepoy Bazar, P.O.:- Medinipur, P.S.:- Kotwali, Pin:- 721101

Memo no.:FSR/0125186211400207

Date: 04-12-2023

**From:**  
Divisional Fire Officer, Paschim Medinipur  
West Bengal Fire & Emergency Services

**To: KABI SUKANTA SECONDARY TEACHERS TRAINING INSTITUTE  
REAPARA, NANDIGRAM, PURBA MEDINIPUR, PIN- 721650**

**Sub: Fire Safety Certificate for existing construction of G+III Storied under group of Educational Building as per NBC Part- IV, in the name & style of "KABI SUKANTA SECONDARY TEACHERS TRAINING INSTITUTE" at Reapara, Nandigram, Purba Medinipur, PIN - 721650.**

This is in reference to your application no. 0125189231400165 dated 28-09-2023 regarding the Fire Safety Certificate for existing construction of G+III Storied under group of Educational Building as per NBC Part- IV, in the name & style of "KABI SUKANTA SECONDARY TEACHERS TRAINING INSTITUTE" at Reapara, Nandigram, Purba Medinipur, PIN - 721650.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

**Recommendation:**

- 1) Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No Parking will be allowed on the Driveway.
- 2) Mummy room of western side staircase shall be constructed within three months.
- 3) LPG Gas bank shall be made outside the Kitchen as per IS specifications and kitchen shall be protected with CO2 extinguisher. Kitchen shall be constructed outside the college building.
- 4) Exit ways shall be marked properly and all exit ways shall remain open during working hours.
- 5) The Interior finish decoration of building shall be made with low flame spread material conforming to the IS Specification.
- 6) To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.

Electrical wiring of the whole building shall have to be carefully checked for any where any tear in them, particularly lines having false ceiling and ducts,

8)The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable of the building.

9)The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.

10)Mock Fire Practice and evacuation drill shall be performed periodically with Participants of all the occupants of the building.

11)Meter room shall be protected with Co2 Fire Extinguisher conforming IS specification,

12)First-Aid Fire Fighting system shall be provided as per I.S specification.

13)Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.

14)Periodical flashing of water in the Hose Reel Hose line / hydrant Valve shall be made to maintain the efficiency working performance of above mention system.

15)If required the old lines shall have to be replace with new lines cables shall always be laid in M.S. conduct pipes continuously bounded to the earth,

16)The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.

17)Revised Fire Safety Recommendation shall be applied for any addition & alternation made in the structure.

18)This Fire Safety Certificate is valid for three years and has to be renewed in every three years from the date of issue of this letter Vide Notification No.- 629\_L dated 17.04.2018 and Memo No.- WBFES/604(200)/2919 dated 01.02.2019.

19)The Renewal Fire Safety Certificate is to be obtained from the Director General, West Bengal Fire and Emergency Services performance of all the life and Fire Safety arrangements and installations of the building.

Validity unknown

Digitally Signed  
Name: Bam Kumar  
Date: 05-Dec-2023 12:02:43  
Reason: Approved  
Location: West Bengal

Member Convener Kharagpur TEC, Paschim  
Medinipur  
West Bengal Fire & Emergency Services